



- NOTES:
1. REMOVE ALL BURRS AND SHARP EDGES
  2. ONE OF THE BAFFLES MUST BE CENTERED BETWEEN DIP TUBES
  3. TANK IS DESIGNED TO SUPPORT GENSET
  4. \*\*TANK TO BE PRESSURE TESTED TO 3 PSI\*\*
  5. TANK TO BE INSTALLED IN ACCORDANCE WITH AFFIXED LABELING, THE FLAMMABLE AND COMBUSTIBLE LIQUID CODES, NFPA 30 AND ANY OTHER PREVAILING CODES
  6. TANK IS DESIGNED AS SECONDARY CONTAINMENT, SINGLE TOP
  7. UNLESS OTHERWISE SPECIFIED; WELD FLANGE FITTINGS TO BE USED
  8. UNLESS OTHERWISE SPECIFIED; TANK TO BE FULLY WELDED
  9. VENDOR TO SUPPLY THE FITTINGS WITH REMOVABLE PLUGS
  10. MATERIAL: 10 GA HRPO, UNLESS OTHERWISE SPECIFIED
  11. \*\*\*ACCESS PANEL TO BE FASTENED WITH 1/4-20 X 5/8 BOLTS\*\*\*
  12. \*\*TANK TO BE UL-C AND UL 142 LISTED\*\*
  13. FINISH: GLOSS BLACK
  14. LIFT BRACKETS TO BE CAPABLE OF LIFTING A TOTAL VERTICAL LOAD OF 10,000# PLUS THE WEIGHT OF THE TANK

Rev	Desc	By	Date
03	CHANGED LIFT BRACKETS	01774	08-03-10
02	ADD UL-C NOTE	01461	04-08-10
01	REVISED NOTES	01362	03-05-10

Beschreibung / Description Tank Part No. / Part No. 100X48X24 24HR	Zeichnung / Drawing No. 90564	Blatt / Sheet 03 / 171
Scale: 0.125 1018.462 D		
SEE NOTES		
TANK SB 240GL DW UL		
100X48X24 24HR		