



- NOTES:
- REMOVE ALL BURRS AND SHARP EDGES
  - ONE OF THE BAFFLES MUST BE CENTERED BETWEEN DIP TUBES
  - TANK IS DESIGNED TO SUPPORT GENSET
  - TANK TO BE PRESSURE TESTED TO 3 PSI\*\*
  - TANK TO BE INSTALLED IN ACCORDANCE WITH AFFIXED LABELING, THE FLAMMABLE AND COMBUSTIBLE LIQUID CODES, NFPA 30 AND ANY OTHER PREVAILING CODES
  - TANK IS DESIGNED AS SECONDARY CONTAINMENT, SINGLE TOP
  - UNLESS OTHERWISE SPECIFIED; WELD FLANGE FITTINGS TO BE USED
  - UNLESS OTHERWISE SPECIFIED; TANK TO BE FULLY WELDED
  - VENDOR TO SUPPLY THE FITTINGS WITH REMOVABLE PLUGS
  - MATERIAL: 3.5 (1.35: 10 GA.) STEEL, ASTM A36 1011, UNLESS OTHERWISE SPECIFIED.
  - ACCESS PANEL TO BE FASTENED WITH 1/4-20 X 5/8 BOLTS\*\*
  - TANK TO BE UL AND UL 142 LISTED\*\*
  - FINISH: GLOSS BLACK
  - LIFT BRACKETS TO BE CAPABLE OF LIFTING A TOTAL VERTICAL LOAD OF 12,500# PLUS THE WEIGHT OF THE TANK

Änderungs-Nr.	Änderungs-Grund	Datum	Gezeichnet	Geprüft
01	CHANGED LIFT EYES	01/74	08-04-10	MTH

Auftrags-Nr. Zeichnungs-Nr. Projekt-Nr. Kunden-Nr.	Zeichnungs-Nr. Blatt Stückzahl	01 1/1 1	92486	1362.346 D	0.125 SEE NOTES TANK SB 370GL DW UL 112X48X34 24HR
---	--------------------------------------	----------------	-------	---------------	---

Für diese technische Unterlage behaltet wir uns alle Rechte vor. Sie darf ohne unsere Zustimmung weder ververvielfältigt, noch Dritten zugänglich gemacht, noch in anderer Weise nachdrücklich verbreitet werden.  
 All rights reserved. This document may not be reproduced or disclosed to a third party or used for any other purpose without our express consent.